


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	HEBS Switches
Name and address of the applicant	LEGRAND FRANCE 128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY 87045 LIMOGES CEDEX FRANCE
Name and address of the manufacturer	LEGRAND FRANCE 128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY 87045 LIMOGES CEDEX FRANCE
Name and address of the factory	
Note: When more than one factory, please report on page 2	<input checked="" type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See Annex
Trademark / Brand (if any)	
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	Series : ZLD15 References : See Annex
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60669-1:1998(ed.3) +A1:1999 +A2:2006 IEC 60669-2-1:2002(ed.4) +A1:2008 IEC 60669-2-5:2013
As shown in the Test Report Ref. No. which forms part of this Certificate	168953-755748

This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 11/02/2021



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: 
Julien Gauthier
Certification Officer

ANNEX

Name and address of the factories:**LEGRAND FRANCE**


128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

BTICINO SPA

4 VIA LUCIANO MANARE
22036 ERBA
ITALY



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Signature: 
Certification Officer

Date: 11/02/2021

ANNEX (End)

Range	Colour											
	White	Titanium	Graphite	Alu	Ivory	Black	Pearly	Magnesium	Champagne	Soft alu	Anthracite	Grey tech
CELIANE	067721	067771	064891									
MOSAIC	077701L											
DOOXIE	600081			600181								
VALENA LIFE	752184			752384	752284	756384						
VALENA ALLURE	752584			752784	752684	752884	752984					
VALENA NEXT	741810			741840		741870						
ARTEOR	574202							574221	574230	574212		

Type reference	References	Nominal characteristics	Terminals	Pattern	contact opening	Method of mounting	Degree of protection	Specificity
ZLD15	See table	300W 100-240V~ 50/60Hz	st	1	without	flush	IP20	Dimmer / switch

st : screw terminal

Mechanisms

Type reference	Trade mark	Specificity
ZLD15	LEGRAND	All ranges

Other characteristics

pattern number	see table
contacts opening	see table
degree of protection	IP 20
method of mounting	see table
method of installation	design A
type of terminals	see table
flexible cable outlet	without

Rated current (A) - rated load (VA or W) :

for 240V~

ZLD15 :

300W halogen lamps
 60 W LED or 10 lamps
 60 W fluorescent compact lamps
 300 VA ferromagnetic transformers for ELV halogen lamps
 300 VA electronic transformers for ELV halogen lamps

Minimum current (A) - minimum load (VA or W) :

ZLD15 : 5W

LCIE – Laboratoire Central des Industries Electriques
 33, avenue du Général Leclerc – BP8
 FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 408 363 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: *Julien Gauthier*
 Julien Gauthier
 Certification Officer

Date: 11/02/2021