

CERTIFICATE

Number: 2140888.01



Issued to:
Applicant:
Niko N.V.
Industriepark West 40
9100, Sint-Niklaas, Belgium

Manufacturer/Licensee:
Niko N.V.
Industriepark West 40
9100, Sint-Niklaas, Belgium

Product(s) : socket-outlets (2-pole)
Trade name(s) : NIKO
Type(s)/model(s) : -3.3+7**-368**

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA Quality hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard IEC 60884-1:2002 + A1:006, NEN 1020:1987 + A2:2004
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900367

KEMA Quality hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 26 November 2010 and expires upon withdrawal of one of the above mentioned standards.

KEMA Quality B.V.

drs. G.J. Zoetbrood
Managing Director

H.L. Schendstok
Certification Manager

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



© Integral publication of this certificate is allowed

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

product	:	socket-outlets (2-pole)
trade name	:	NIKO
type	:	-3.3+7**-368**
method of mounting	:	surface type
cover	:	housing of thermoplastic material
terminals	:	screwless terminals
rated current	:	16 A
rated voltage	:	250 V~
degree of protection	:	IP55 completely closed IP44 with IP44 plug inserted
earthing	:	with side earthing-contacts
design	:	safety socket-outlet
programm	:	HYDRO
markings	:	-tradename, series-indication and electrical ratings on the base -tradename and suffix for the cover on this part

Additional information

The in this certificate mentioned type should be used in combination with the housings as mentioned in our KEMA certificate 2140888.06.

TESTS

Test requirements

IEC 60884-1:2002 + A1:2006
NEN 1020:1987 + A2:2004

Test result

The test results are laid down in KEMA Quality test file 2140888.01.

Remarks


This certificate is also based on the CEBEC CB Test Certificate BE-2420.

Conclusion

The examination proved that all test requirements were met.

Tested by : SGS CEBEC

Checked by : H.R.M. Barends



Factory locations

Niko N.V.

Industriepark West 40, 9100, Sint-Niklaas

Belgium

LICENCE N° 2140888.01

HOW TO READ THIS CERTIFICATION LICENCE?

As *end product references* (cfr. catalogues, website, packaging, ...) aren't identical to *certification references* (cfr. certification licences), you'll find below an explanatory table.

Niko declares that the *end product references* in the left column correspond with the *certification references* in the right column.

End product reference	Certification reference
700-36805, 700-37845, 700-37846, 701-36805, 761-36805	-3.3+7**-368**

Sint-Niklaas, 15/12/2014



Rony Haentjens
Certification & Standardization Officer