

CERTIFICATE

Issued to:
Applicant:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Licensee:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Product : housings
Trade name(s) : NIKO
Type(s)/model(s) : 7**-73000, 7**-74000, 7**-75000, 7**-83101, 7**-83201, 7**-84101, 7**-84102, 7**-84111, 7**-84112, 7**-84201, 7**-84202, 7**-84211, 7**-84212, 7**-84302, 7**-84801, 7**-84802 and 7**-84902

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60669-1:2018, NEN 1020:2019, NEN-IEC 60884-1:2019, NEN-IEC 60884-1:2019/A1:2019 and NEN-IEC 60884-1:2019/A2:2019
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900367

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 7 May 2020 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-113236

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



M. Triulzi
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: housings
Trade name(s)	: NIKO
Type(s)/model(s)	: 7**-73000, 7**-74000, 7**-75000, 7**-83101, 7**-83201, 7**-84101, 7**-84102, 7**-84111, 7**-84112, 7**-84201, 7**-84202, 7**-84211, 7**-84212, 7**-84302, 7**-84801, 7**-84802 and 7**-84902
Programm	: HYDRO
Markings	: -tradename and series- indication of the housing

Product data – type 7-73000**

Housing : special flush-type housing for one function

Product data – type 7-74000**

Housing : special vertical flush-type housing with two functions

Product data – type 7-75000**

Housing : special horizontal flush-type housing with two functions

Product data – type 7-83101**

Housing : singular housing of thermoplastic material, provided with membranes

Product data – type 7-83201**

Housing : two-fold vertical housing of thermoplastic material, provided with membranes

Product data – type 7-84101**

Housing : singular housing of thermoplastic material, provided with one grommet M20

Product data – type 7-84102**

Housing : singular housing of thermoplastic material, provided with two grommets M20

Product data – type 7-84111**

Housing : singular housing of thermoplastic material, provided with two grommets M20

Product data – type 7-84112**

Housing : singular housing of thermoplastic material, provided with three grommets M20

Product data – type 7-84201**

Housing : two-fold vertical housing of thermoplastic material, provided with one grommet M20

Product data – type 7-84202**

Housing : two-fold vertical housing of thermoplastic material, provided with two grommets M20

Product data – type 7-84211**

Housing : two-fold vertical housing of thermoplastic material, provided with two grommets M20

Product data – type 7-84212**

Housing : two-fold vertical housing of thermoplastic material, provided with three grommets M20

Product data – type 7-84302**

Housing : three-fold vertical housing of thermoplastic material, provided with two grommets M20

Product data – type 7-84801**

Housing : two-fold horizontal housing of thermoplastic material, provided with one grommet M20

Product data – type 7-84802**

Housing : two-fold horizontal housing of thermoplastic material, provided with two grommets M20

Product data – type 7-84902**

Housing : three-fold horizontal housing of thermoplastic material, provided with two grommets M20

TESTS**Test requirements**

EN 60669-1:2018
NEN 1020:2019
NEN-IEC 60884-1:2019
NEN-IEC 60884-1:2019/A1:2019
NEN-IEC 60884-1:2019/A2:2019

Test result

The test results are laid down in DEKRA test file 224284900.

Additional information

This certificate is also based on the SGS CEBEC CB Test Certificates BE-8195 and BE-8228

This certificate replaces certificate No. 71-103413 which we herewith declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory location

Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium