

THORGEON

SENSORS

PIR MOTION SENSOR

02007



Manufactured in PRC



400W



360°



6m



220-240V



800W



50-60



IP20



THORGEON



www.thorgeon.com

SIA "ATTA-1", Daugavgrivas street 77,
Riga, Latvia, LV-1007



4751029890443

Developed in Latvia

Sensor utilizes the infrared energy from human as control-signal source and it can start the load at once when one enters detection field. It can identify day and night automatically. It is easy to install and used widely.


SPECIFICATION:

Power Sourcing: 220 -240V/AC
 Power Frequency: 50/60Hz
 Ambient Light: <3-2000LUX (adjustable)
 Time Delay: Min.10sec±3sec
 Max.15min±2min
 Rated Load: 1200W ⚡
 300W ⚡
 300W LED

Detection Range: 360°
 Detection Distance: 6m max(<24°C)
 Working Temperature: -20~+40°C
 Working Humidity: <93%RH
 Power Consumption: approx 0.5W
 Installation Height: 2.2-4m
 Detection Moving Speed: 0.6-1.5m/s

FUNCTION:

- Can identify day and night: The consumer can adjust working state in different ambient light. It can work in the daytime and at night when LUX knob is adjusted on the "sun" position (max). It can work in the ambient light less than 3LUX when it is adjusted on the "3" position (min). As for the adjustment pattern, please refer to the testing pattern.
- Time-Delay is added continually: When it receives the second induction signals within the first induction, it will restart to time from the moment.





INSTALLATION ADVICE:

As the detector responds to changes in temperature, avoid the following situations:


- Avoid pointing the detector towards objects with highly reflective surfaces, such as mirrors etc.
- Avoid mounting the detector near heat sources, such as heating vents, air conditioning units, light etc.
- Avoid pointing the detector towards objects that may move in the wind, such as curtains, tall plants etc.




CONNECTION:

 <p>WARNING</p>	<p>Warning. Danger of death through electric shock!</p> <ul style="list-style-type: none"> • Must be installed by professional electrician. • Disconnect power source. • Cover or shield any adjacent live components. • Ensure device cannot be switched on. • Check power supply is disconnected.
	

- Turn clockwise the plastic cover that is on the top of sensor and adjust time and LUX knob.
- Loose the screws in the connection terminal, and then connect the power to connection terminal of sensor according to connection-wire diagram.
- Fold the metal spring of the sensor upwards, until they are in "I" position with sensor, and then put the sensor into the hole or installation box which is on the ceiling and has the similar size with the sensor. Releasing the spring, the sensor will be set in this installation position.
- After finishing installing, turn on the power and then test it.




CONNECTION-WIRE DIAGRAM:



TEST:

- Turn the TIME knob anti-clockwise on the minimum (10s). Turn the LUX knob clockwise on the maximum (sun).
- Switch on the power; the sensor and its connected lamp will have no signal at the beginning. After Warm-up 30sec, the sensor can start work. If the sensor receives the induction signal, the lamp will turn on. While there is no another induction signal any more, the load should stop working within $10\text{sec} \pm 3\text{sec}$ and the lamp would turn off.
- Turn LUX knob anti-clockwise on the minimum (3). If the ambient light is more than 3LUX, the sensor would not work and the lamp stop working too. If the ambient light is less than 3LUX (darkness), the sensor would work. Under no induction signal condition, the sensor should stop working within $10\text{sec} \pm 3\text{sec}$.



Note: when testing in daylight, please turn LUX knob to ☀ (SUN) position, otherwise the sensor lamp could not work!

SOME PROBLEM AND SOLVED WAY:

- The load does not work:
 - Please check if the connection of power source and load is correct.
 - Please check if the load is good.
 - Please check if the settings of working light correspond to ambient light.
- The sensitivity is poor:
 - Please check if there is any hindrance in front of the detector to affect it to receive the signals.
 - Please check if the ambient temperature is too high.
 - Please check if the induction signal source is in the detection field.
 - Please check if the installation height corresponds to the height required in the instruction.
 - Please check if the moving orientation is correct.
- The sensor can not shut off the load automatically:
 - Please check if there is continual signal in the detection field.
 - Please check if the time delay is set to the maximum position
 - Please check if the power corresponds to the instruction.